

State Code Requirements

State	Requirement
Arizona	ASME Code piping package w/P-6 data form.
California	High and low water alarms on all boilers 10 HP to 150 HP.
	Low-NOx equipment on all boilers (3 HP and larger) installed in Los Angeles, Orange, Riverside, San Bernadino, and Ventura counties.
California (San Francisco)	Requires two motorized gas valves.
Colorado	ASME Code piping package w/P-6 data form.
Connecticut	Additional motorized gas valve for boilers 60 HP to 150 HP.
	McDonnell Miller controls with snap switches only (no mercury).
D.C.	Brass piping (steam side).
Hawaii	Low water level alarm 5 HP to 150 HP.
Indiana	ASME Code piping package w/P-6 data form.
Iowa	ASME Code piping package w/P-6 data form.
Kentucky	"U" stamped blowdown separators.
Maine	McDonnell Miller controls with snap switches only (no mercury).
Maryland	Additional motorized gas valve for boilers 60 HP to 150 HP.
Massachusetts	High and low gas pressure switches for 30 HP to 50 HP.
	Additional low water relay, manual reset for 1.5 HP to 10 HP.
Michigan	"U" stamped blowdown separators.
Nebraska	ASME Code piping package w/P-6 data form
Nevada	Low-NOx equipment on all boilers 25 HP and above
	Additional low water level alarm.
New York (Long Island)	Additional gas valve 60 HP to 150 HP
	High and low gas pressure switches for 30 HP to 50 HP.
Ohio	ASME Code piping package w/P-6 data form.
Oregon	Low water level alarm.
Pennsylvania	Additional motorized gas valve for boilers 60 HP to 150 HP.
Rhode Island	McDonnell Miller controls with snap switches only (no mercury).
Texas	Low-NOx equipment on all boilers up to 50 HP.
Vermont	Requires McDonnell Miller 157.
Virginia	Additional motorized gas valve for boilers 60 HP to 150 HP.
Wisconsin	ASME Code piping package w/P-6 data form.

